

庵治実験ハウス発電及び消費電力記録

月	2009/10月																															合計
日付	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
発電量KW			18	19	7.1	3.3	0.7	9.2	9.8	18	19	19	11	14	17	17	14	12	15	8.7	15	8.7	18	5.9	3.8	1.5	15	15	15	14	16	361
消費電量KW			14	11	13	12	13	14	13	13	12	14	14	15	13	14	16	12	17	13	17	13	18	17	15	17	16	15	18	18	16	421.6
売電量KW			13	16	3.2	0.6	0	5	6.2	14	15	14	6.6	9.6	14	13	9.3	9.9	11	6.1	11	6.1	11	1.7	0.9	0	11	11	9.9	8.9	11	249.4
買電量KW			9.1	7.2	9.1	9.9	13	9.9	8.8	8.7	8	9	9.3	11	9.6	9.8	11	9.3	13	10	13	10	10	13	12	16	11	11	13	13	12	309.2
発電使用量			5.3	3.5	3.9	2.7	0.7	4.2	3.6	4.5	3.8	4.7	4.4	4.7	3.7	4.5	4.8	2.4	4	2.6	4	2.6	6.7	4.2	2.9	1.5	4.3	3.5	4.8	5	4.1	111.6
天候			晴	快晴	曇	雨	雨	曇	曇	晴	晴	晴	晴曇	晴曇	晴	晴	晴曇	晴	晴曇	曇	晴	晴曇	晴曇	曇	曇	雨曇	晴	晴	快晴	晴曇	快晴	
平均温度	24	24	24	22	20	19	19	20	19	18	18	18	19	19	18	19	21	20	19	19	17	17	18	18	19	18	18	17	17	18	19	19.126

月	2009/11月																															合計
日付	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
発電量KW	4.2	9.3	17	17	7.9	13	14	9.6	6.5	2.6	1.7	4.6	6.4	11	5.9	6.2	0.6	14	6.9	13	10	2.8	14	2.6	5.1	14	11	2.6	9.1	7.8	250.8	
消費電量KW	16	20	30	18	18	17	19	16	17	16	15	18	18	16	18	20	19	21	34	35	35	41	33	32	28	28	29	27	30	29	712.3	
売電量KW	1.4	5.7	14	12	4.2	8.6	9.3	5	3	0.5	0	1.9	2.9	6.3	2.2	2.2	0	10	3.2	8.4	5.6	0.3	10	0	2.4	9.5	7.7	0.5		4.7	140.9	
買電量KW	13	16	27	13	14	12	14	11	14	13	13	15	14	13	14	15	18	17	31	30	31	38	30	29	25	24	25	24		25	580	
発電使用量	2.8	3.6	3.6	5.2	3.7	4.7	4.9	4.6	3.5	2.1	1.7	2.7	3.5	4.3	3.7	4	0.6	4.2	3.7	4.8	4.5	2.5	3.4	2.6	2.7	4.3	3.7	2.1	9.1	3.1	109.9	
天候	雨晴	晴曇	晴	晴曇	曇	晴	晴	晴曇	曇	曇雨	雨曇	曇	曇晴	曇晴	晴曇	曇	雨	晴曇	曇晴	晴曇	晴曇	曇雨	晴	曇雨	曇雨	快晴	晴曇	曇	晴曇	晴曇		
平均温度	17	14	10	12	15	16	17	17	18	18	17	15	17	17	14	12	8.4	11	11	10	11	9	11	11	14	12	13	13	9.4	11	13.39	

月	2009/12月																															合計
日付	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
発電量KW	12	10	1.5	14	13	9.9	14	9.2	5.3	2.3	0.7	6.6	8.2	13	9	8.6	11	14	10	8.9	8.8	8.4	5.1	9.3	13	8.1	13	10	12	7.2	13	287.6
消費電量KW	32	32	26	31	32	30	33	35	36	33	28	28	30	37	35	36	48	44	49	39	37	43	35	37	37	36	41	37	41	41	48	1126.7
売電量KW	8.4	6.7	0.1	10	9.2	6	10	6.3	2.8	0.3	0	3.6	4.8	8.4	5.1	5.4	6.4	9.5	4.6	5.6	5.1	5	2.6	5.1	8.8	4	8.4	6.3	7.6	4.5	6.1	177.1
買電量KW	28	28	24	28	29	26	29	32	34	31	27	25	27	33	31	33	44	40	43	35	33	39	33	33	33	32	37	33	37	38	42	1014.8
発電使用量	4	3.6	1.4	3.6	3.3	3.9	3.9	2.9	2.5	2	0.7	3	3.4	4.8	3.9	3.2	4.3	4.1	5.7	3.3	3.7	3.4	2.5	4.2	3.8	4.1	4.5	3.7	4	2.7	6.4	110.5
天候	快晴	晴	雨曇	晴	晴曇	曇晴	晴曇	晴曇	曇雨	曇	曇雨	曇	晴曇	晴	曇	晴曇	晴	晴雪	晴曇	晴雪	晴曇	晴	曇雨	曇晴	晴曇	晴曇	晴	曇晴	曇晴	曇晴	曇晴	
平均温度	11	11	11	11	12	9.2	7.5	8.4	8.7	10	14	15	11	9.8	8.7	6.7	5.1	4	4.3	6.4	5.6	6.3	6.6	7.5	8	8.9	6.1	6.1	4.4	6.5	3.3	8.1774

■ 床下暖房全開    ■ 床下暖房半開    ■ エアコン稼働